



*Specialists in School Buildings*

DATE: March 5, 2015

RE: Change Order No. 20  
Board Summary

Project: New Woodland High School

---

Change Order 20 amount: \$25,033.00

- CCD 104 – This was an additional cost to paint revised accent colors in the North Shared Activity space. Original colors were not acceptable to many.
- CCD 105 – The lighting controls in the classrooms are not functioning as designed. This charge paid the contractor to install a diode into the affected light fixtures to test a possible solution. The solution was successful and this repair will need to be implemented on each classroom as well as in other spaces with daylight dimming controls.
- CCD 106 – No cost change to revise the “W” logo on the synthetic turf field.
- CCD 107– Revise the size of the steel planting benches in the green house to match the standard tray used by the horticulture program for a more efficient use of space. Also add 2 additional benches.
- CCD 108 – Provide natural gas piping from the main building to the green house as fuel for the space heaters. No piping to greenhouse shown on drawings.
- COP 061 – No cost change to revise casework in Culinary Arts to accommodate rolling flour and sugar bins.
- COR 241– Provide security call boxes and electric strike control at rear of building at service door 1600FA and service yard door 1600FB for afterhours delivery access. No controls shown on drawings.
- COR 271 – Additional wiring and outlet to provide power to operate the projector in the main Gym. Power not shown on drawings.
- COR 273 – Additional wiring and outlet to provide power to mechanical room air dryer on AC unit. Power not shown on drawings.

#### CSG Office Locations

ESD 112  
2500 NE 65th Avenue  
Vancouver WA 98661  
P 360.750.7500  
F 360.750.9706

ESD 101  
4202 S Regal Street  
Spokane WA 99223  
P 509.789.3800  
F 509.456.2999

ESD 123  
3918 W Court Street  
Pasco WA 99301  
P 509.547.8441  
F 509.544.5795

ESD 171  
430 Olds Station Road  
Wenatchee WA 98801  
P 509.665.2610  
F 509.662.9027

NW ESD 189  
1601 R Avenue  
Anacortes WA 98221  
P 360.299.4000  
F 360.299.4070

- COR 278 – Additional metal trim around horticultural cooler to close off exposed walls. No trim shown on drawings.
- COR 281 – Change to add one additional ADA dishwasher and revise exhaust hood at range in Life Skills.
- COR 297 – Add condensate drain on air handling unit in mechanical room. Drain not shown on drawings.
- COR 298 – Provide natural gas regulator in green house. Regulator not shown on drawings.

End